



**TYPICAL SECTION**  
SCALE: 3" = 1'-0"

SUSPENSION REQUIREMENTS  
SEE DETAIL A1.2

1-5/8" X 1-5/8" UNISTRUT P1000  
- 12 GA. STEEL PRIMARY CHANNEL

12" MAX UNISTRUT  
OVERHANG, TYP.

4'-0" MAX VERTICAL  
SUPPORT SPACING, TYP.

**NOTE:**  
THREADED ROD ATTACHMENT  
TO UNISTRUT AND STRUCTURE  
ABOVE DESIGNED AND  
PROVIDED BY OTHERS.

BEAM PROFILE  
SEE DETAIL A1.1

HANGER BRACKET  
SEE DETAIL A1.3

BAFFLE SPLICE  
SEE DETAIL A1.4

1-5/8" X 1-5/8" UNISTRUT P1000 -  
12 GA. STEEL PRIMARY CHANNEL  
SEE DETAIL A1.2

BAFFLE END CAP  
SEE DETAIL A1.4

\*MINIMUM TWO (2) SUPPORT  
BRACKETS REQUIRED PER  
BEAM SEGMENT

4'-0" TYP. UNISTRUT SPACING, 6'-0" MAX\*

2'-0" MAX BAFFLE  
OVERHANG, TYP.

THREADED ROD ATTACHMENT  
TO UNISTRUT AND STRUCTURE  
ABOVE DESIGNED AND PROVIDED  
BY OTHERS. THREADED ROD BY  
OTHERS. SEE DETAIL A1.2

6" BAFFLE SPACING SHOWN,  
ACTUAL CAN VARY, TYP.



**TYPICAL ELEVATION**  
SCALE: NOT TO SCALE

**INTERIOR INSTALLATION**

**HunterDouglasContract**

**CEILING**

5015 Oakbrook Parkway, Suite 100  
Norcross, GA 30093  
800-366-4327 / 770-806-9557  
fax: 770-806-0214

All rights reserved. This drawing  
is the property of Hunter  
Douglas and may not be copied  
or multiplied neither wholly nor  
partly. It may not be submitted  
for perusal to third parties  
either.

www.hunterdouglascontract.com

**SPECIFICATIONS**  
(unless noted otherwise)

MATERIAL: EXTRUDED ALUMINUM ALLOY 6063-T5  
FINISHES: PAINT / POWDER COAT / DECORATED WOOD  
PERFORATION: NOT AVAILABLE

**TOLERANCES**  
(unless noted otherwise)

DECIMAL: .0 +/- .060  
.00 +/- .030  
.000 +/- .010  
FRACTIONAL: +/- 1/32"  
ANGULAR: +/- 1/2° (.5°)

**LUXALON**  
METAL CEILINGS

**WoodWright**  
WOOD CEILINGS

**Techstyle**  
ACOUSTICAL CEILINGS

**OVERALL ISOMETRIC VIEW**

PROJECT: HIGH PROFILE SERIES VERTICALLY CURVED SPECIFICATIONS  
DRAWING NUMBER: HPS-VCURVE-A1.0  
PART NUMBER: N/A  
SCALE: AS SHOWN  
DATE: 8/26/14  
DRAWN BY: HDAP ENGINEERING